

11/11/24	S-21	Chidhaachari	Bathroom light is not working	work completed
11/11/24	S-31	Atcharya	Bulb holder changed	Muthu Karthikeyan
11/11/24	G-16	Tubelight not working (Meenakshi Madan)	Fan not properly working	key
11/11/24	S-21	Kalairani	Tubelight not working. 2w LED bulb changed	Muthu S. Karthikeyan
11/11/24			⊗ Bathroom light not working	work completed 8/11/24 Muthu S. Karthikeyan
11/11/24			Bulb holder changed 9w Bulb changed	
11/11/24	First floor Heater	Heater Not working	Heater fault rectified	work completed Muthu S. Karthikeyan
11/11/24	S-22	Main door lock has to be changed	→ Entry in civil note	(Varshini)
11/11/24	S10	Both Fans regulator is not working		ok
11/11/24	G-9	Washroom light NOT WORKING	→ Pushpasri Rakshana Ramya	Rakshana
11/11/24	F-24	1) Washroom light (dim)	1 nos 9w LED Bulb changed; Fan regulator not changed - work completed.	Lehyan
11/11/24		2) fan regulator broken		P. Rami
11/11/24	S10	Both fans regulator is not working	9w LED - 1 nos Fan Regulator changed, work completed.	DEAN
11/11/24		Bathroom light not working		AGAR MEDICAL COLLEGE & HOSPITAL
				RATHNAMANGALAM, KANAKOTTAIYUR POST, Chennai - 600127
				20/11/24
				P. Rami

19/11	F-8 ✓	Fan is not working. water dripping from above fan is shaking and making sound	Vaishali	Vaishali 1. No Fan changed P. the Shukla
19/11	G-6 ✓		Nandhini	Nandhini P. Sakthi Prakash work completed
20/11	S-7	Bathroom light is not working	meekha	work completed Vinay / meekha
23/11	F-3	Fan making more noise	Priyanka see	work completed Vinay / meekha
30/11	G-5 Door lock	Bathroom light fused fuse to 13 pole Chd.	Jenita Elaine	work completed S. Arthim, Sakthi
01/12	S-1 ✓	Bathroom light Not working	Rushmi	work completed Anirudh Karthik work completed
2/12	Door lock F-22	Bathroom light is not working		work completed Anirudh Karthik 04/12/24
2/12	F-5	Fan not working Fan Normal working	Sowgandhika	work completed S. Arthim, Sakthi
5/12	S-13	Fan not working (fan set chd)	Dhanisha	work completed S. Arthim, Sakthi
6/12	S-31	plugboard has to be checked Switch fault attend.	Barshini	work completed S. Arthim, Sakthi
9/12	F-4	Bathroom Light get Fused	Dhanisha	
13/12	G-5	Room tube light fused	Jelani	

9/9/24	F-27	(1) Bathroom flush tank ↳ water leakage (2) Clamp broken. (3) Water drainage problem.	AL Diso.	Completed
28/9/24	S13	(1) Bathroom - hand faucet not working		
28/09/24	S8	(1) - Bathroom - hand faucet not working (2) - left side wall full of fungus and water (3) - leaky at the roof during rainy time		
28/9/24	S28	(1) Water problem in wash basin (2) Due to Kanaryang fungus need to spray insecticide in the cup (3) Sometimes, water is not coming in the washroom tap as well	Angie	Completed the work
0/9/24	F26	(1) Bathroom water is not draining properly. (drain blocked) (2) Water leaking from toilet flusher box	thuy	
1/10/2024	S21	(1) Flush is broken (2) Tap in sink is not working.	October 2	Dean TAGORE MEDICAL COLLEGE & HOSPITAL RATHINAMANGALAM, MELAKOTTAIYUR POST, Chennai-600 127.

Inform to
CS/Dept.

10/24	S-1	Fan is repair Fan is running normal	Also light sound is coming in the room.	Work Completed.
10/29	F-4	Bathroom pipe not working properly	Mansur	work done
10/30	S-6	Bathroom water not draining after bathing.	Mansur	4/10/24
8/10	F-30	Door to window repair	Dr	
7/10	B-21 ON	1) Bathroom flush broken 2) sink tap not working	H. K. K.	Kalam Mansur Ran
1/10	S-28	Insecticide	Any	
11/10	S-21 ON	Flush is not working		
8/10	S-30	Hand shower is not working	Any	S-30-1
8/10	OK	Wash Basin ^{Pipe} is leaking		
8/10	S-1	Flush not working Wash basin pipe is leaking Wash basin is clogged	Chel	- Spring
8/10	S-1	Wash basin is leaking emergency.	Chel	Why U are not correct if this room compl
23/10	F-30	Window repair (emergency)	Dr	
24/10	F-31	sink is blocked	Dr	Informed to De
24/10	B-3	Health faucet has algal growth CHANGE IT		DEAN TAGORE MEDICAL COLLEGE & HOSPITAL RATHINAMANGALAM, MELAKOTTAIYUR POST, Chennai-600 127.

03/10/24, 5.22.2024, 17/11/24
SR, 5.20.24
30,
Paint work today

03.11.24 Room 12
Q11

03.11.2024
Complaint

flush not working

Sir Sri name
Sri R.

S. S. S.
complaint

11/24 Dr-3

Water flow in flush.

Dr. N.S.

11/24 F-32

Poor, slow water flow in tap
takes long to fill.

5/11/24

Flush is not working
in bathroom

Kalaiyari

11/24

11/24 F-31

(Complaint before 1 month)

11/24 F-26

Stove in bathroom
not working, deep cleaning

P. S. S. DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAIYUR POST,
Chennai-600 127.

6/11/24.

S21

- * Bathroom flush not working
- * washbasin tap not working

Blalavani



NOTE

⇒ This is the 5th time I'm writing this no action has been taken since a month kindly make it as soon as possible.



11/24

S22

Nails needed. kindly do it as soon as possible

Infirmary & Canteen Dept

11/24

T 16

Nails needed to hang clock.

Hegde

11/24

~~S20~~

Fence regulator is not working

Varshini

8/11/24

S22

main door lock has to be changed

Varshini

DATE	ROOM NO	NAME OF STUDENTS	COMPLAINTS	WORKER REPORT (STAFF)	Sign & Worker with the names
11/11/24	F-24	Lakshmi priya	Washroom pipe broken	<u>labaya</u>	
11/11/24	S-5	Harini Kavaga Sowmi	washbasin pipe water not coming	→	S. mugundh
11/11/24	G-14	S. pashikavasi	Shower dummy (stopper) leakage.	dummy change work done	- Mugundh
			X. Heeter		
3/11/24	F-24	Grovartamani	Bathroom both taps problem	Completed 18/11/24.	

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAIYUR POST,
Chennai-600 127.

13/11/24	(F-30)	Panikro.	Window repair		
14/11/24	E-16	Drinipatharathi	Fan repair	(Change drum)	
15/11/24	F-12	Atchaya	Water not filter properly in the bathroom. & outside the room the dustbin can not placed. It looks messy in the corridor.	<u>Allure</u>	Completed Saswara (W)
16/11/24	(G-14)	S. Yashitani	Bathroom door broken, not able to lock door.	Yashitani	Done
18/11/24	F-3	Prayanshu	Bathroom lock broken		Done
18/11/24	F16	Warden	Tap leaking (Bathroom)	(Change sink pipe)	Done Completed work
18/11/24	F6	Munthi	Bathroom tap, water less flow		Done
18-11-24	F28.	Jaranya.	Bathroom front tap, less water flow		Completed by
18.11.24	(F-20)	Juno. hi	Main door not working its not pull or push.		Completed by 23/11/24
22.11.24.	F28.	Jaranya.	Washroom tap leak	TNR...	
26.11.24	F-3	Nithya chaitanya	Fan is stopped and sound is coming		
27.11.24	S.A. Sb	Aishwarya L.S.	Water not draining in wash room.		Completed by
1/12/24	F8	Varshika.	Water leaking from ceiling	VSR	delay work
4/12/24	F20	Juno. hi	Washroom latch lock is broken		
9/12/24	G13	F. Jigani	Washroom. Toilet flush is broken.		

JULY 2024.

NO	DATE	ROOM NO.	NATURE OF COMPLAINT	Signature of STUDENT	Signature of Staff
1.	4/7/24	F-30	Leakage of water from flush tank	Elfi	→ Done
2.	4/7/24	S-3	Ward Hanger.	Rf.	
3.	4/7/24	F-5	Cupboard door broken. Fix it.	Radha	
4.	6/7/24	S 30 Lock	Washbasin pipe leaking Jet spray worsened & leaking.	A. Alila	
5	7/7/24	F 32	Shower knob not working properly Water leaking constantly	Tesavarukin V	→ Done
6.	7/7/24	S 22	Main door lock is not there	Elfi	
7.	8/7/24	S 11	Washroom - holes are present earthworms are coming	Elfi	

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM - MELAKOTTAIYUR POST,
Chennai - 600 127.



DATE	ROOM NO	REPORT	DEAN	STAFF
8/7/24	F-28	Room lock broken.	Shufok	STAFF
9/7/24	S-28	Washroom flush is not working properly.	OK	
12/7/24	S-12	waterflow is very slow in bathroom Informed to A.C.	OK	
16/7/24	S-16	washroom jet spray is not working properly.		
18/7/24	S-30	Bathroom light is not working	jamni	
18/7/24	S-30	Bathroom Jet Spray is leaking.	A. Aliah	
19/7/2024	S-17	Handshower is broken. Please repair it asap.	Bhavana K.T	
22/7/24	F-31	Water stagnating in wash basin	V. Jyoti	
22/7/2024	(S-17)	Handshower is broken. Please repair it asap	Bhavana K.T	
22/9/2024	(F-28)	Toilet flush not working	Chell	
22/7/24	F-26	wash basin - Not draining properly	P. Shudhy	
22/7/24	S-22	washroom flush - leaking from Tub.		
27/24	S-22	No door lock in our room		
23/7/24	SF-6	instead they fixed nails which is causing damage to us. Rot problem	DEAN	

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MEDAKOTTAHUR POST,
Chennai-600 127.

24/7/24	S29	Water is leaking from the tap. <u>Tap should be changed in washbasin</u>	Fig	F29 Rm
25/7/24	S16	Toilet seat cover is broken	Q	
27/7/2024	S-17	Hand shower is broken. Please repair it asap	S	F23 S17 S29 S22-Doorwc
31/7/2024	S21	Water is leaking from the tap	FD	
1/08/2024	S3	Door stopper Need Nail	gill	

2/8/24	F1	One washing machine is not working properly. Again & again it shows error.	PD	
4/8/24	F-23	Toilet flush is not working	Chir/Chirab	Civil
2/8/24	F-H	In bathroom, Pipe was not properly worked	✓	
-/08/24	S-16	Toilet Problem	✓	Complete
9/08/24	S31	Sink tap should be check.	✓	
12/8/24	S18	Cupboard is damaged	✓	Board give

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
BATHAMUNDA, DIST. BANGALORE
CHINTY

11/8/24

E-6

Crack on the wall

20/8/24

F-24

Bathroom tap leaking

Iron stand not working

Ushini

Sahayya

Complaint label PED

22/08/24

F-27

Water leak from wash basin
water overflowing in the flush tank

Infra work done by Mr. Subash

22/8/24

F-17

Bathroom Tap is not working

Informing

22/8/24

F-25

well
Bathroom door is broken

27/8/24

F-17

Bathroom tap is missing

Infra

Tap not in place by 10.10.24

28/8/24

S29

We cannot able to lock the door. Please come and see what's the problem

Infra

30/8/24

S26

Flush is not working

Infra

31/8/24

G20

Bathroom lock not working

Infra

3/9/24

F05

Bathroom door

Room door (be name of room)

6/9/24

F4

Bathroom tap not working

Infra

7/9/24

F6

Rat trouble, Please change the bathroom window net

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
MADHURAMANGALAM, MELAKOTTAIYUR POST,
Chennai-600 127.

5/12

S13

Dhanisha

Room fan not working

Bathroom - hand faucet not working

Do it immediately
(Examine)

DATE
Work Completed by Mr. D. K. S. S.

16/12

F-15

Sanika

Bedroom - pipe is leaking

DATE

17/12/24

G1-11

SIVASHRI R

Bathroom - flush not working

DATE

Signature
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAIYUR POST,
Chennai-600 127.

Date	From	Complaints
10/6/24	Getard F-100	Rathnam Water heater Not Working (3, 4, 5) From

25/6/24	S26	3 Noils
25/6/24	S32	3 Noils
25/6/24	S32	3 Noils
25/6/24	S32	3 Noils

19/6/24	S6	From Not Working
---------	----	------------------

19/6/24	S6	Nails (1) loaded	(3 Noils)
	S1	Nails 1 loaded	
	S2	Nails 1 loaded	
	S6	Nails 1 loaded	
	S17	Nails 1 loaded	(24 Noils)
	S20	Nails 1 loaded	(3 Noils)
	S25	Nails 1 loaded	
	S28	Nails 1 loaded	
	S12	Nails 1 loaded	
	F32	Nails 1 loaded	
	F4	Nails 1 loaded	
	F31	Nails 1 loaded	
	F13	Nails 1 loaded	

Date	From	Feed back
12/6/24	Getard F-100	Water heater working Normal but water from not coming. Please call plumber if required

12/6/24	S26	work completed
	S32	work completed
	S32	work completed
	S32	work completed

19/6/24	S6	Changed the from (1) Noils work completed
---------	----	--

20/6/24	S6	work completed
20/6/24	S20	work completed
20/6/24	S25	work completed
20/6/24	S28	work completed

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAIYUR POST,
Chennai-600 127.

Date	No	Complaints	Date	Room No	Feed Back
	S24	Nails Needed			
	S14	Nails Needed			
	S47	Nails Needed			
	S13	Nails Needed (3 nails)	28/6/24	S13	work completed 
	S26	Nails Needed	29/6/24	S26	work completed 
	S16	Nails Needed			
	S121	Nails Needed	29/6/24	S12	work completed 
	S27	Nails Needed			
6/24	Ground Floor	G18 - Store Room Total light Not working	29/6/24	Floor G18 - S6	Tube light changed work done work completed 
3/24	F-4	work needed.			
6/24	(S-5)	fan not working switches not working Plaster not working. Need 2 rollers 3 nails needed for tying rope. Need a chain Need a row of 1	26/6/24 1/7/24	F4 → S5 → S5 →	door lock door lock Nails fixed. Cots changed. 
3/24	F-32	Fan → change to long fan light → dim → change light	26/6/24	F32 →	Light 

DEAN
THERAPY & HOSPITAL
RATHINAPALLE, MELAKOTTAIYUR POST,
Chennai-600 127.

Room No.	Complaints	Date	Room No.	Work done
20/6/24	G11 Fan Regulator Not Working No.11 Needs - (2)	26/6/24	G11	Regulator changed work completed
21/6/24	First Floor Total light 100% both room	26/6/24	First Floor	Tube light changed work done.
22/6/24	Ground Floor Tiles Problem	26/6/24		
23/6/24	First Floor Ceiling Water Leakage.	26/6/24		See the complaint only.
25/6/24	G115 Fan running slow	26/6	G115	Capacitor changed work done.
25/6/24	G112 Tube light not working		G112	Tube light changed work done
25/6/24	G12 - Tube light dim	27/7/24	G12	Tube light (1) - nos changed.
26/6/24	G11 Change emergency net		G11	
27/6/24	G20 Switch box - fan not plug not working	1/7/24	G20	Door lock.
27/6/24	1st Floor Sink (Wash-basin leakage)	1/7/24	1st Floor	Wash basin leakage problem completed work
28/6/24	1st Floor Fan sound, light dim, milk heater - (2) (Neethu)	1/7/24	F28	Door lock.
6/7/24	1st Floor 1-32 Small fan → Big fan light dim → change it	1/7/24	F32	Tube light changed.

Date	Room No	Complaints	Names	Date	Room No	Feed Back
17/24	S-27	Plug not working.	Aishwarya	17/24	S-27	Changed - 1st plug work done (New one)
17/24	(F-15)	Switch not working	Sanyasmita		F-15	Switch (1) - nos changed work done
3/7/24	G-20	Switch not working on 4 plug Not working	Suman (C-2)	3/7	G-20	Switch (3) nos changed work done
3/7/24	F-28	Fan not working Sound. Dim light (C-2)	Neelam	3/7	F-28	Fan New one changed Tube light changed work done
3/7/24	S5	Fan not working Switches Not working (plug not working (C-2) working	Sachin's son	3/7	S5	Fan New one changed Switch changed plug fault rectified work done
17/24	S3	Needed one fan (S-3)		3/7	S3	Room locked. Moving 10/1/24. routine
17/24	G-9	Switch. Unable to on. Nails Needed - (2)	Karpyagam	3/7	G-9	Switch (2) nos changed. work done
17/24	F-20	Fan working very slow	Varsha fan capacitor - 100 changed with wiring	18/07/24	F-20	100s Fan capacitor changed with wiring complete
17/24	S-21	Fan - sound shaking.	Geetha		S-21	Fan capacitor - 100 changed fan - 100. DBAN work done
6/24	Second Floor	Water heater Not working		6/7/24	Second Floor	The plumber came and checked the water heater - 800 (222) and it was good. Electrical side

	NO	INCHARGE	COMPLAINTS	DATE	No	WORK DONE
5/7/24	Second Floor	Third Floor	2nd floor Post Paint. There is a black spot in the rest room. where the water does not flow.	6/7/24	Third Floor	Block of water in the rest room. work done
5/7/24	Second Floor	5th floor	Pass in gun is running low on water.	6/7/24	Second Floor	work done
6/7/24	BF-31	Usha	Small fan, slow speed mosquito net tear.	10/7/24	F-31	fan capacitor - not changed. work done
6/7/24	F-32	Sudha	small fan, speed - slow. light - dim - change.	10/7/24	F-32	Tube light - not changed. fan normal condition. fault rectified. work done
6/7/24	1st floor	1st floor	2nd, 3rd Rest room blockage.	9/7/24	1st Floor	2nd 3rd - Rest room blockage problem Rectified. work done
8/7/24	1st floor	Sangeetha	fan not working (fume coming)	9/7/24	F-15	Fan Capacitor changed work done
10/7/24	First floor	1st floor	Kangaroo Infracone light not working. room 3 toilet light not working.	10/7/24	1st floor	OSW (3rd) New LED tube light fix. work done.
10/7/24	Ground Floor	Ground Floor	Corridor Tube light in Not working in side Bath room side.	14/7/24	Ground floor	OSW (2nd) New LED Tube light fix. work done. <i>gudhar</i>

Dr. K. DEAN
VAIGORE MEDICAL COLLEGE & HOSPITAL
 RATHINAMANGALAM, MELAKOTTAIYUR POST,
 Chennai-600 127.

No	Computer	Entrance - fan running slow	14/7/24	No	Roomed plan	1 was Carpenter charged, work completed. qd. 1/2/24
10/7/24	Ground Floor					
12/7/24	F5	Access	Na	30/7/24	F5	Fixed nail - work done.
29/7/24	(S-16)	blowdown (8778471612)	making for 201 below	5/8/24	S6.	Carpenter work completed
5/8/24	F24	2 nd Floor	Tiles problem	5/8/24	1 st Floor	
7/8/24	1 st Floor	Wash basin blocked		5/8/24	1 st Floor	Wash basin Complaint rectified work done
7/8/24	1 st Floor	current trip problem		15/8/24	1 st Floor	work done
5/8/24	Ground Floor	Part of fan problem		5/8/24	Ground Floor	problem rectified.
18/24	First Floor	Wash basin blocked		9/8/24	First Floor	Wash basin blocked Complaint rectified
		2 nd Bathroom lock broken.			2 nd Bathroom	New door lock fixed (work done)
14/2/24	First floor	3 rd Bathroom lock broken		16/2/24	First Floor	3 rd Bathroom - Complaint rectified - work done
		1 st & 2 nd bathroom heater not working			2 nd Bathroom	Heater problem rectified work done.
4/2/24	Second Floor	2 nd Floor Water heater not working		15/2/24	Second Floor	At hand the Complaints
14/2/24	1 st Floor	Switch broken (Corridor)		19/2/24	1 st Floor	At hand the Complaints New switch installed, work done
14/2/24	1 st Floor	The Tube light is hanging		19/2/24	F21	The Tube light is hanging The right Chain 600 Comp done



Date	Room No	Name	Complaints	Date	Room No	Feed Back
19/9/24	G18	Kiran	Plaster done - plaster (gypsum) finished for mosquito	20/9/24	G18	attend the complaint
01/08/24	F-13	Manmath	fan not working	26/9/24	F-13	Attend the complaint. work completed. New fan fixed.
12/9/24	F-11	Mathay	door handle already changed	19/9/24	F-11	Plumber attend the complaint
12/9/24	S-13	Deepthika	MOSQUITO NET	-	-	
3/9/24	S-6	Divyavani	MOSQUITO NET			
23/9/24	S-15	Pooja	MOSQUITO NET			
21/9/24	S-16	Prati	MOSQUITO NET			
21/9/24	S-11	divya	MOSQUITO NET			
11/9/24	G132	Elakkiya	Fan Not working.	21/9/24	G132	Capacitor changed. work done
25/9/24	F-14	Pradeesh	Fan not working	25/9/24	F-14	Capacitor changed. work done
25/9/24	F-14	Pradeesh	Mosquito net		F14.	

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM MELAKOTTAIVUR POST,
Chennai-600 127.



Date	Room No	Names	Complaints	Date	Room No	Food Back
26/11/24	G11	Rathina Angelina	Spark from the switch board Dum tube light	25/11/24	G11	1 nos 95 watts LED Tube light changed. Switch board. Fault attended. work completed. G. Viswanath N. Divanah
29/9/24	S28 <u>F-7</u>	Nithyaahiree	Fan (ceiling) is loose	03/10/24	S. 28	1 nos remaining Fan changed. work completed. G. Viswanath / Divanah
30/9/24		Murugika	carpenter work - railing.	10/10/24	F 7	carpenter work completed
30/9/24	G4-10	Masilin	Nails for change - Carpenters work.	10/10/24	G10	carpenter work completed
12/10/24	G6	Kethazi	Need to change mosquito net chain	26/10/24	G6	work completed
14/10/24	F18	Vardaa	Need to change mosquito net			
23/10/24	Ground Floor		Bathroom side Toilet light (2) not working	23/10/24	Ground Floor	Tubelight 2 nos changed work done
26/10/24	Second Floor		Bathroom 1st/2nd water blockage	27/10/24	Second Floor	blockage problem cleared. work done
26/10/24	Second Floor		Wash basin blocked water	27/10/24	Second Floor	Wash basin water blockage complained cleared work done.
31/11/24	Ground floor. (G-13)	Akshaya	Fan speed running speed is slow.		1st floor	
7/11/24	1st Floor		Flush flow slow (1, 2) - Toilet		1st Floor	Problem rectified. (1, 2) Toilet work done

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAIYUR POST,
Chennai-600 127.

Date	Room No	Name	Complaints	Date	Room No	Work Done
6/11/24	Ground Floor	Ground Floor	Toilet - Fans it - gun damaged (3rd Rest Room)			
12/11/24	G-9	Tharagan	Fan is Making Sound.		G-9	Changed the fan with new one
14/11/24	1st Floor Bathroom Side		Tube light not working.		1st Floor Bathroom Side	Tube light Changed (1) - NOS - work done
18/11/24	G15	Ground Floor	Fan Sound.		1st Floor	Changed work completed.
18/11/24	Reception Side	Ground Floor	6 Model Box (new) Needed	19/11/24	Ground Floor	Fixed New one box (6 Model) - Type Box work done
18/11/24	Boys room 8th flr	Ground Floor	Needed New Connection for water heater	20/11/24		
27/11/24	F-17	SONA	Fan - Sound.	03/12/24	F-17	1ms Fan changed.
30/11/24	8-20	Vijayalakshmi	Light not working.	3/12/24	S-20	1ms 85 watts LED Tube light changed.
30/11/24	1st Floor	S-21 to Shalini	WiFi Connection is slow.	3/12/24	S-21	WiFi Connection to Internet working. Fan capacitor 1ms changed
2/12/24	F-14	Raj's Pradeep	Fan not working	3/12/24	F-14	Fan capacitor 1ms changed



Date	Room No.	Names	Complaints	Date of admission	Room No.	Lead Rate
2/12/24	F-20		Light Not working		-	1 nos as water LED Tube light changed
9/12/24	Ground Floor	Rest Room Side	Bath room side Tube light Not working	9/12/24	Ground Floor	1) - nos Led light changed. work done
10/12/24	G-9	Karpagam	Light is Hanging. going to fall			
01/12/24	G-7	Blessy	Light is Hanging. going to fall			

DEAN
 TAGORE MEDICAL COLLEGE & HOSPITAL
 RATHINAMANGALAM, MELAKOTTAIYUR POST,
 Chennai-600 127.



JUNE 2024				EoB		
S.No	DATE	Room NO	STUDENT NAME	NATURE OF COMPLAINT	SPAN STUDENT	REMARK WITH SIGNATURE ELECTRICIAN
1	04.06.24	G17	Madhu mittu	FAN not working	-	1st fan working for changed with 1st fan on 06/06/24
2	04/06/24	visitor waiting hall side		Fan nos required.	-	was with needed fan fixed. was with needed fan fixed.
3	4/6/24	F22	K. Lavi Bravathi	Switch board regulator gets loose. -> Bathroom lock gets loose	Shy	
4	5/06/24	GT-04	ARANTICA	Cupboard broken because of termite. [Already informed 4 months ago.]	Arantika	
5	5/6/24	F26	Harishkrani	Tube light Fuse	Shy	

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAIYUR POST,
Chennai-600 127.

5th 9th 10th 11th 12th 13th 14th 15th 16th 17th 18th 19th 20th 21st 22nd 23rd 24th 25th 26th 27th 28th 29th 30th 31st

Completed by

DEAN

TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAIYUR POST,
Chennai-600 127.

25.06.24 The light of the room
and the fan of the room
completed by the
electrician.

E.B.

S.no	DATE	Room no	STUDENT NAME	STUDENT SIGN.	NATURE OF COMPLAINT	STAFF USE ONLY	REMARK WITH SIGNATURE
6.	6/6/24	F-9	S. Karthika	S. Karthika	25W LED Tube light not working on preferal goods side. Heater is not working on fitting changed.		25W LED Tube light not working on preferal goods side. Heater is not working on fitting changed.
7.	7/6/24	S-17	S. Karthika	S. Karthika	Tube light is dim unable to study.		Tube light is dim unable to study.
8.	10/6/24	F-4	S. Karthika	S. Karthika	Increased Fan speed.		Increased Fan speed.
9.	11/6/24	S-25	N. Karthika	N. Karthika	Through fan		Through fan
10.	11/6/24	S-2	P. Karthika	P. Karthika	Room light not working		Room light not working
11.	15/6/24	S-12	V. Karthika	V. Karthika	Two light down		Two light down

S.no	DATE	Room no	STUDENT NAME	STUDENT SIGN.	NATURE OF COMPLAINT	STAFF USE ONLY	REMARK WITH SIGNATURE
12.	18/6/24	S-22	V. Karthika	V. Karthika	Fan is not working		Fan is not working
13.	18/6/24	F-18	N. Karthika	N. Karthika	Fan is not working		Fan is not working
14.	19/6/24	S-20	N. Karthika	N. Karthika	Fan is not working		Fan is not working
15.	20/6/24	F-8	S. Karthika	S. Karthika	Light not properly working (Right side)		Light not properly working (Right side)
16.	20/6/24	F-8	S. Karthika	S. Karthika	Switch box repair		Switch box repair
17.	20/6/24	S-10	S. Karthika	S. Karthika	Fan speed der		Fan speed der

DEAN
TAGE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAIYUR POST,
Chennai-600 127.

Fan speed der
Fan is not working
Fan is not working

Fan is not working
Fan is not working
Fan is not working

STAFF USE ONLY
REMARK WITH SIGNATURE

25W LED Tube light not working on preferal goods side. Heater is not working on fitting changed.

STAFF USE ONLY
REMARK WITH SIGNATURE

E.B.

DATE 23.6.24 F1 Hops

STUDENT NAME OF SIGNATURE
 17. 23.6.24 F1 Hops
 18. 23/6/24 F32 JERARDIN JAY
 24/6/24 F. 8 Polina
 23/6/24 F32 Polina

DATE 23.6.24 F1 Hops
 17. 23.6.24 F1 Hops
 18. 23/6/24 F32 JERARDIN JAY
 24/6/24 F. 8 Polina
 23/6/24 F32 Polina
 21. 27/7/24 S-30 A. Akila
 2. 27/7/24 F-24 (F-24) Lakshmi
 3. 27/7/24 F-24 (F-24) Lakshmi
 4. 27/7/24 F-24 (F-24) Lakshmi
 5. 27/7/24 F-24 (F-24) Lakshmi
 6. 27/7/24 F-24 (F-24) Lakshmi
 7. 27/7/24 F-24 (F-24) Lakshmi
 8. 27/7/24 F-24 (F-24) Lakshmi
 9. 27/7/24 F-24 (F-24) Lakshmi
 10. 27/7/24 F-24 (F-24) Lakshmi
 11. 27/7/24 F-24 (F-24) Lakshmi
 12. 27/7/24 F-24 (F-24) Lakshmi
 13. 27/7/24 F-24 (F-24) Lakshmi
 14. 27/7/24 F-24 (F-24) Lakshmi
 15. 27/7/24 F-24 (F-24) Lakshmi
 16. 27/7/24 F-24 (F-24) Lakshmi
 17. 27/7/24 F-24 (F-24) Lakshmi
 18. 27/7/24 F-24 (F-24) Lakshmi
 19. 27/7/24 F-24 (F-24) Lakshmi
 20. 27/7/24 F-24 (F-24) Lakshmi
 21. 27/7/24 F-24 (F-24) Lakshmi
 22. 27/7/24 F-24 (F-24) Lakshmi
 23. 27/7/24 F-24 (F-24) Lakshmi
 24. 27/7/24 F-24 (F-24) Lakshmi
 25. 27/7/24 F-24 (F-24) Lakshmi
 26. 27/7/24 F-24 (F-24) Lakshmi
 27. 27/7/24 F-24 (F-24) Lakshmi
 28. 27/7/24 F-24 (F-24) Lakshmi
 29. 27/7/24 F-24 (F-24) Lakshmi
 30. 27/7/24 F-24 (F-24) Lakshmi
 31. 27/7/24 F-24 (F-24) Lakshmi
 32. 27/7/24 F-24 (F-24) Lakshmi
 33. 27/7/24 F-24 (F-24) Lakshmi
 34. 27/7/24 F-24 (F-24) Lakshmi
 35. 27/7/24 F-24 (F-24) Lakshmi
 36. 27/7/24 F-24 (F-24) Lakshmi
 37. 27/7/24 F-24 (F-24) Lakshmi
 38. 27/7/24 F-24 (F-24) Lakshmi
 39. 27/7/24 F-24 (F-24) Lakshmi
 40. 27/7/24 F-24 (F-24) Lakshmi
 41. 27/7/24 F-24 (F-24) Lakshmi
 42. 27/7/24 F-24 (F-24) Lakshmi
 43. 27/7/24 F-24 (F-24) Lakshmi
 44. 27/7/24 F-24 (F-24) Lakshmi
 45. 27/7/24 F-24 (F-24) Lakshmi
 46. 27/7/24 F-24 (F-24) Lakshmi
 47. 27/7/24 F-24 (F-24) Lakshmi
 48. 27/7/24 F-24 (F-24) Lakshmi
 49. 27/7/24 F-24 (F-24) Lakshmi
 50. 27/7/24 F-24 (F-24) Lakshmi
 51. 27/7/24 F-24 (F-24) Lakshmi
 52. 27/7/24 F-24 (F-24) Lakshmi
 53. 27/7/24 F-24 (F-24) Lakshmi
 54. 27/7/24 F-24 (F-24) Lakshmi
 55. 27/7/24 F-24 (F-24) Lakshmi
 56. 27/7/24 F-24 (F-24) Lakshmi
 57. 27/7/24 F-24 (F-24) Lakshmi
 58. 27/7/24 F-24 (F-24) Lakshmi
 59. 27/7/24 F-24 (F-24) Lakshmi
 60. 27/7/24 F-24 (F-24) Lakshmi
 61. 27/7/24 F-24 (F-24) Lakshmi
 62. 27/7/24 F-24 (F-24) Lakshmi
 63. 27/7/24 F-24 (F-24) Lakshmi
 64. 27/7/24 F-24 (F-24) Lakshmi
 65. 27/7/24 F-24 (F-24) Lakshmi
 66. 27/7/24 F-24 (F-24) Lakshmi
 67. 27/7/24 F-24 (F-24) Lakshmi
 68. 27/7/24 F-24 (F-24) Lakshmi
 69. 27/7/24 F-24 (F-24) Lakshmi
 70. 27/7/24 F-24 (F-24) Lakshmi
 71. 27/7/24 F-24 (F-24) Lakshmi
 72. 27/7/24 F-24 (F-24) Lakshmi
 73. 27/7/24 F-24 (F-24) Lakshmi
 74. 27/7/24 F-24 (F-24) Lakshmi
 75. 27/7/24 F-24 (F-24) Lakshmi
 76. 27/7/24 F-24 (F-24) Lakshmi
 77. 27/7/24 F-24 (F-24) Lakshmi
 78. 27/7/24 F-24 (F-24) Lakshmi
 79. 27/7/24 F-24 (F-24) Lakshmi
 80. 27/7/24 F-24 (F-24) Lakshmi
 81. 27/7/24 F-24 (F-24) Lakshmi
 82. 27/7/24 F-24 (F-24) Lakshmi
 83. 27/7/24 F-24 (F-24) Lakshmi
 84. 27/7/24 F-24 (F-24) Lakshmi
 85. 27/7/24 F-24 (F-24) Lakshmi
 86. 27/7/24 F-24 (F-24) Lakshmi
 87. 27/7/24 F-24 (F-24) Lakshmi
 88. 27/7/24 F-24 (F-24) Lakshmi
 89. 27/7/24 F-24 (F-24) Lakshmi
 90. 27/7/24 F-24 (F-24) Lakshmi
 91. 27/7/24 F-24 (F-24) Lakshmi
 92. 27/7/24 F-24 (F-24) Lakshmi
 93. 27/7/24 F-24 (F-24) Lakshmi
 94. 27/7/24 F-24 (F-24) Lakshmi
 95. 27/7/24 F-24 (F-24) Lakshmi
 96. 27/7/24 F-24 (F-24) Lakshmi
 97. 27/7/24 F-24 (F-24) Lakshmi
 98. 27/7/24 F-24 (F-24) Lakshmi
 99. 27/7/24 F-24 (F-24) Lakshmi
 100. 27/7/24 F-24 (F-24) Lakshmi

No	DATE	Sl. No	Location	Work Done	Remarks
1.	8/7/24	11	Shiveta dama danyaga	Sl. No Sams Sams	
2.	9/7/24	827	Shiveta dama danyaga	Sl. No Sams Sams	
3.	14/7/24	F32	Jeyarathna Sathya Sams	Sl. No Sams Sams	
4.	18/7/24	S30	A. A. H.	Sl. No Sams Sams	
1.	26/7/24	F45	Vinodh Kumar	Sl. No Sams Sams	
1.	30/7/24	Gym		Sl. No Sams Sams	
1.	31/7/24	529	Manikumar	Sl. No Sams Sams	

3/8/24 F30 Monica All. Tubelight is not working

13/8/24 1st 2nd floor Ayman AC fan fault rectified. work completed.

16/8/24 9th floor Passage Tubelight not work. 25W LED 11 no. work complete. R. Chinn

17/8/24 S-14 Divyashree Bed Fan is not working in full speed. 2 nos capacitor S. Kanakia

20/8/24 G16 ~~F1~~ Tube light not working. 25W LED Tube light - no change. weak complete. S. Kanakia

20/8/24 S29 North in Fan is blinking too slow. Oil

29/8/24 G-18 Fan not working. Fan - G-7 Room Current not working. 014

4/9/24 F-28 Permana Power supply not coming to Iron Box

7.09.24 F-11 Anubha, A. Apt. One fan is stopped working. 30m tubelight is very dim & therefore brightness is very less. is just about to start. One fan set off.

24/9/24 S-2 S. Jayashankar

TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAIYUR POST,
Chennai-600 127.

18/9/24	F-2	Sharma, B. V.	on duty: B. V.	on duty: B. V.
21/9/24	S 2	S Prayagdas	on duty: S. Prayagdas	on duty: S. Prayagdas
21/9/24	F-3	V. Subramanian	on duty: V. Subramanian	on duty: V. Subramanian
24/09/24	(F-11)	Amal, G.	on duty: Amal, G.	on duty: Amal, G.
25/9/24	F-3	Prasanna	on duty: Prasanna	on duty: Prasanna
25/9/24	F-24	S. Lakshmi	on duty: S. Lakshmi	on duty: S. Lakshmi
25/9/24	F-14	Ashwarya, M.	on duty: Ashwarya, M.	on duty: Ashwarya, M.
25/9/24	F-3	Pinku	on duty: Pinku	on duty: Pinku
25/9/24	S 8	P. R. Monika	on duty: P. R. Monika	on duty: P. R. Monika
3/10/24	S 21	Mausha, M. S.	on duty: Mausha, M. S.	on duty: Mausha, M. S.
17/10/24	F-3	Nithya Chaitanya	on duty: Nithya Chaitanya	on duty: Nithya Chaitanya

Form is making move. Pls separate it (2nd floor near wall)

DEAN completed

TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAH, POST,
Chennai-600 127.

Room floor not
light not working.
2nd floor step-tube
work. (complaint)
Plumber is working.
water (complaint)
NOT complete
Bridging work
change the work

Plumber
Vimray
Muthu

on duty: B. V.

on duty: S. Prayagdas

on duty: V. Subramanian

on duty: Amal, G.

on duty: Prasanna

on duty: S. Lakshmi

on duty: Ashwarya, M.

on duty: Pinku

on duty: P. R. Monika

on duty: Mausha, M. S.

on duty: Nithya Chaitanya

7/10/24	S-20	Yuvazani	Fan is not working Handshower is not working	work completed 9/10/24
	S-21	chi	Fan slow for calibration (Chil... with backlight)	work completed 9/10/24
	F-23	Vaish	Fan is not working	work completed 9/10/24
9/10/24	F-31	Tharavai	light is blinking 52 watts LED chd.	work completed 9/10/24
	F-16	Fan		

24/10/24	S-2	Nayan	Bathroom light not working door lock.	Inform all EB Muthu Dinash.
5/11/24	G-13	Light (7. Light) not working	25W LED Tube light changed Completed	
5/11/24	G-2	Tube light not working	25W LED Tube light changed Completed	Muthu Dinash.
1/11/24	F-21	Haridharan. P	Fan not working. Main switch trip.	S. Kenthirayan P. Mari
	P-26	Jhanika Velam	Room No- 13 th Fan Removal Final. to P-26 Room Room locked. Fan cut & inter chd.	
	F-16	Fan not working.		
	S-5	Fan not working Naveena	Fan not working	
11/12/24	G-9	Fan not working (ramp)	Fan set chd.	
11/12/24	G-13	Bathroom light i Jhogan lakshmi	Bathroom light B/wb chd.	DEAN TAGORE MEDICAL COLLEGE & HOSPITAL RATHINAMANGALAM, MELAKOTTAYUR POST, Chennai-600-127. 10 main

DATE	COMPLAINT	LOCATION	ROOM NO	WORK DONE	PERFORMED SIGNATURE	WARRANT SIGNATURE
19/01/03	PL-Seminars room PU S-10 ALL stabilizer line not working	S-10		Stabilizer problem	S. Senthil R. Rul	
19/01/03	ALL stabilizer line not working PU BLOCK S-20	S-20		work complete	S. Senthil R. Rul	
19/01/03	Fan & Tube light not working	G-13		new fan have to be change	S. Senthil R. Rul	
19/01/03	can't Boyle chandel just floor varanda light not working A nos	A nos		work complete	S. Senthil R. Rul	
19/01/03	can't Boyle chandel bathroom is toilet light not working	2 nos		work complete	S. Senthil R. Rul	
24/1/03	AC stabilizer line not working in block S-5			work complete	S. Senthil R. Rul	
25/1/23	plug points not working, Tube light not working	F-33		Regulator - INO, fan - INO, 25W LED tube light - INO. changed Tube light fault rectified.	work completed	
28/1/23	Tube light not working, electrical damage	F-11		Door lock	Huthu	
28/1/23	Fan regulator not working available	G-14		Fan regulator	S. Senthil S. Senthil	13/2
31/01/23	Tube light not working	G-28		Fan regulator tube light Bulb changed	S. Senthil S. Senthil	13/2
07/02/23	Fan stop working	F-24		F16 Fan not working. work complete	S. Senthil S. Senthil	13/2

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAYUR POST,
Chennai-600 127.

DATE	NAME	Room No	YER.	CELL NO	COMPLAINT	SIGNATURE
26.09.23	Praveen K	2	III	8220813239	Charging socket not working Tubelight - fuse Door lock not working Need nails in wall for mirror	Praveen K
21.07.23	SARAN	45	III	634044352	3rd Floor toilet Header not working & there is no proper closed	Saran
24/8/23	Gadwin	75	II	9930240119	Tubelight is not working	Gadwin
1/8/23	Vignesh	48	IV	7010478910	Room is running slow. Bathroom Beside Room Tubelight not working. Holder for zero watt Bulb	Vignesh
15/07	Saravanan	40	IV	999473235 (whatsapp call only)	Tubelight change the wall side	Saravanan
15/12/23	Vignesh	48	IV	7010478910	Need to change the fan zero watt Bulb holder	Vignesh

DEAN

TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAYUR POST,
Chennai-600 127.



date Name Room No Year Class

Complaint

Sign

Remarks

11/08/23	T. MOHAMMAD NURAFI	38	IV th yr	8203580524	Electronics. and glass window not working	Sign	
19/12/23	D. Mohamed Fayez	33	IV th yr	994266 8794	Fan not working Tube light not working	Sign	Electronics
19/12/23	A. Ravi Varma	14	1 st year	9957841308	Tube light not working	A. R. Varma	
12/12/23	R. Dharmarajan	35	3 rd year	91113058302	Tube light not working Fan " " " Refrigerator " "	Sign	Electronics
19/12/23	Abhinav Sood J-A	43	4 th year	854470321	Tube light with damaged switch. Switch	Abhinav Sood	Electronics
19/12/23	Venkatesh A	50	4 th year	9445723066	Fan not working properly (broken)	Sign	Electronics
19/12/23	Divya Shankar	24	3 rd year	7939301700	Light is not working 25W LED light changed	Divya	Electronics 11/12/23. 9.00
01/14/23	Karthik	61	1 st yr	9176637267	Fan not working properly one light is not working	Sign	Electronics 08/12/23

Date	Name	Phn	Address	Remarks
16.09.23	Rabikan S	60	1001011111	Good morning. Water not coming. Spent 1 hour on it. 24/9/23
18.09.23	Harsha M	60	1001011111	Good morning. Water not coming. Spent 1 hour on it. 24/9/23
20/9/23	Manish	60	1001011111	Good morning. Water not coming. Spent 1 hour on it. 24/9/23
22.09.23	Thangarajugobal S	52	1001011111	Good morning. Water not coming. Spent 1 hour on it. 24/9/23
24/9/2023	Radhakrishnan S	60	1001011111	Good morning. Water not coming. Spent 1 hour on it. 24/9/23
05/10/23	Sigmesh. NGA	12	1001011111	Good morning. Water not coming. Spent 1 hour on it. 24/9/23
09/10/23	Prasanna Kumar	10	1001011111	Good morning. Water not coming. Spent 1 hour on it. 24/9/23
09/10/23	Harish	11	1001011111	Good morning. Water not coming. Spent 1 hour on it. 24/9/23
17/10/23	Verkooban A	30	1001011111	Good morning. Water not coming. Spent 1 hour on it. 24/9/23

Date	Name	Room No.	Yr	Roll No	Complaint	Remarks
16/9/23	3rd year 1st floor	28	1 st	637605575	Heater not working in Room near Room No. 27.	Repaired
16/9/23	2 nd Floor Vardaan Dhanush	51	1 st	927415751	Fan slow	Repaired
16/9/23	Peetabak	40	1 st	960667045	change the position of light	Repaired
18/9/23	Nandakumar E	73C	1 st yr	9566556263	Fan working slow	Repaired
18/9/23	Vignish	48	1 st yr	7010178110	Fan is not working properly Making Sounds. unable to Read	Repaired
21-9-23	Shashik.	30	1 st yr	110860008	Fan is too slow Its too hot and mosquitoes biting.	Repaired
22/9/23	K. Nithin Kumar	33A	1 st yr	9080281490	"change fan", not at all working	Repaired
22/9/23	Yaswanth Kumar	21	1 st yr	848055161	Fan not working.	Repaired
22/9/23	Yaswanth	13	1 st yr	8220909114	Light not working	Repaired
23/9/23	Nani	26	1 st yr	879044551	Tube light not working	Repaired

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKKAL
Chennai-600 127.

D	Date		Room no.	Electrical Complaint		year	Phone no	Mechanic Signature	Remarks
	24/10/24		47	1 st fan not working	IV		8220819224		work done
	4/11/24		59	2 nd fan not working	II		87806911742		work done
	4/11/24		1 st floor	1 light not working (New light required)					work done
	4/11/24		2 nd floor Room: 47	1 st Fan very noisy (Sound)	IV		6381221664		work done
	5/11/24		2 nd floor	2 nd floor B side A Tube light hanging					work done
	6/11/24		1 st floor	Room no 20 fan not working					work done
	9/11/24		2 nd floor	1 st floor hot water machine not working with not working					
	10/11/24		1 st floor	Fan making sound, regulator not working					
	10/11/24		3 rd floor	Wi-Fi - Not coming in second wing (11 year)			9597398796		
	12/11/24		Room no: 40	2 nd fan slow	Door lock				work completed
			Room no: 44	2 nd fan sound over fan - no change					11/24
			Room no: 46	2 nd fan sound & slow	fan fault rectified				11/24
			Room no: 47	1 st fan sound	fan - no change				11/24
	13/11/24		Room no: 20	2 nd fan runs slow with sound	fan (11 year)		9629128997		
	14/11/24		1 st floor	In water dispenser					
				hot water is not coming	(11 year)		9629128997		
	14/11/24		Room no: 14	fan Regulator change	fan regulator - 2 no changed				

DEAN
TJAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAYUR POST,
Chennai-600 127.

Sl. No.	Phone No.	Year	Electrical Complaint	Electrical Sign	Remark
2		I st	1 light in hall was connected - Circuit changed for 2nd fan blowers (2) fan regulator (2) night lamp (1)	OK work completed	work completed P. Prasad
60		II nd	Fan is not working for past 3 days	9445129391 Fan changed ok	
33A		III rd	Fan is not working	(9730897666) Fan changed ok	
35		I st	Fan is not working properly regulator problem and fan slow	9123539668 Work done	
72		II nd	Tubelight is not working	956656263 Tubelight was changed work completed T.V.J.	
74		II nd	Fluorescent not working (8watts) light	8810574167	
73A		2 nd	3 tube not work		work completed - ok Mr. Pd.
35		I st	Fan Sound is noise	9123539668	work completed - ok Mr. Pd.
5		I st	wifi not connecting	8270721694	

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAYUR POST,
Chennai - 600 127.



9/6/24	9/6/24	Completed	Fan Repair. - Fan no stock. work Follow	19/6/24 86	Food Bank
G-32	G-32		Switch board broken. 8M Switch board. Ceiling fan slow. new switch sheet changed. work completed. <u>vinay</u> <u>namthakumar</u> .		Changed fan New one work completed
10/6/24			<u>Second Floor</u> Bathing stall 3, 4, 5 hot water not working. Heater working normal but water flow not coming. Please (Floor worker) <u>vinay</u> <u>namthakumar</u> .	19/6/24	Electrical fault rectified work completed Vinay - Namthakumar
10/6/24	F-30		Switch box fault. Electrical fault rectified. work completed. <u>vinay</u> <u>namthakumar</u> .		1 Nos 25 watts Led Tube light changed. work completed Vinay Namthakumar.
10/6/24		II Floor	II Floor bath room light not working. 1 nos 25 watts LED Tube light changed. work completed. <u>vinay</u> <u>namthakumar</u> .	(II Floor) 15.6.24	Bathroom F30 - work done
F-8	F-8		Fan speed is slow. one ceiling fan removed from S-3 Room. this fan fixed in Room No: F-8. F-8 ceiling fan removed for service to power house.	19/6/24	Work complete. Karthikayan Namthakumar.
F-33	F-33		Switch board broken.		Switch board loose Connection Rectified Complaint. (work done) <u>Anbu</u> <u>Ma</u>
S-28	S-28		Switchboard near window broken.		S28 - Room lock
F-33	F-33		Tiles near door broken (Tiles problem)		
S-28	S-28		Tiles near door broken (Tiles problem)		

DEAN
TAGORE MEDICAL COLLEGE & HOSPITAL
RATHINAMANGALAM, MELAKOTTAIYUR POST,
Chennai-600 127.